



Annexure C


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Rc.No. 181 / SHP / DM&HO / Medchal / 2024 - 25

Dated: 10 / 06 / 2024.

It is certified that an inspection team headed by Y. Vijay Kumar, Health Inspector, Medchal Malkajigiri District, from DM&HO Office (Health Department) and Vasudha enviro labs Pvt.Ltd, Kukatpally, Hyderabad - certified PHED have inspected **CMR School**, Sy No. 91(P),92,93,152(P),159,160,161,162,163(P),164,165,167,168/1,168/2,169,170 & 171, NJR & KLR Nagar, Medchal Village & Municipality, Medchal Mandal, Medchal - Malkajigiri District on 10-06-2024 and on the basis of Water Test Report (Attached) bearing No VMR - 0246 - 0624, dated: 10-06-2024 from Vasudha enviro. labs Pvt.Ltd, Kukatpally, Hyderabad (PHED Lab) certified that the **CMR School** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This Certificate is valid for a period of One year from date of issue.


District Medical & Health Officer
Dist. Medical & Health Officer
Medchal Malkajigiri District

To
The Principal,
CMR School,
Sy.No. 91(P),92,93,152(P),159,
160,161,162,163(P),164,165,167,168/1,
168/2,169,170 & 171, NJR & KLR Nagar,
Medchal Village & Municipality, Medchal Mandal,
Medchal Malkajigiri District..

Principal
CMR School, Medchal


Secretary & Correspondent
CMR School Medchal

VASUDHA

enviro labs Pvt. Ltd.

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-40203910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VMR - 0246 - 0624
M/s. CMR School Sy Nos: 91(P),92,93,152(P),159,160,161,162,163(P) 164,165,167,168/1,168/2,169,170 &171, NJR & KLR Nagar, Situated at Medchal (V) & Municipality, Medchal(M), Medchal- Malkajgiri(D), Telangana.		REPORT ISSUE DATE	10 th June 2024
		REGISTRATION NO.	VEL/1460
		REGISTRATION DATE	07 th June 2024
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	Drinking Water	REFERENCE DATE	--
		ANALYSIS STARTING DATE	07 th June 2024
SAMPLE SITE	--	ANALYSIS COMPLETION DATE	10 th June 2024
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000 ml	
SAMPLE COLLECTED OR SUBMITTED		By Client	

TEST RESULTS

S.NO	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
Physical Parameters					
1	pH	--	IS 3025 P - 11	6.98	6.50 - 8.50
2	Conductivity	µs/cm	APHA	33.5	Not Specified
3	Colour	Hazen	IS 3025 P - 04	0.0	< 5
4	Turbidity	NTU	IS 3025 P - 10	0.0	< 1
5	Total Dissolved Solids	mg/l	IS 3025 P - 16	16.75	< 500
Chemical Parameters					
6	Total Alkalinity as CaCO ₃	mg/l	IS 3025 P - 23	12	< 200
7	Total Hardness as CaCO ₃	mg/l	IS 3025 P - 21	8	< 200
8	Calcium as Ca	mg/l	IS 3025 P - 40	1.60	< 75
9	Magnesium as Mg	mg/l	IS 3025 P - 46	0.97	< 30
10	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P - 21	0	Not Specified
11	Carbonate Hardness as CaCO ₃	mg/l	IS 3025 P - 21	8	Not Specified
12	Sodium as Na	mg/l	IS 3025 P - 45	1.0	Not Specified
13	Potassium as K	mg/l	IS 3025 P - 45	0.5	Not Specified
14	Fluoride as F	mg/l	IS 3025 P - 60	0.1	< 1.0
15	Chlorides as Cl	mg/l	IS 3025 P - 32	8.01	< 250
16	Sulphates as SO ₄	mg/l	IS 3025 P - 24	2.0	< 200
17	Nitrates as NO ₃	mg/l	IS 3025 P - 34	0.05	< 45
18	Iron as Fe	mg/l	IS 3025 P - 53	0.02	< 0.3
Microbiological Parameters					
1	Escherichia coli	Presence	IS 5887 P - 01	Absence	Should be absent
2	Total Coliforms	Presence	IS 5887 P - 01	Absence	Should be absent
3	Total Plate Count	CFU/ml	IS 5402	02	< 100

REMARKS

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water specification desirable limits.

Remarks: All parameters are within the limits.

Renu Prinsipi
CMR School, Medchal
Prasanna
Chemist



Ch. S. J.
Secretary & Correspondent
CMR School Medchal
Authorized Signatory